

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Ida B Wells - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
126-DF1894-A-007-A	Weight Room	10/28/2022	10/31/2022	A2J0960-01	Lead	ND	0.2	15	ppb
126-DF1899-A-007-A	Hallway (Yoga Room)	10/28/2022	10/31/2022	A2J0960-02	Lead	ND	0.2	15	ppb
126-DF1900-A-007-A	Hallway (Classroom 29)	10/28/2022	10/31/2022	A2J0960-03	Lead	ND	0.2	15	ppb
126-DF1910-A-007-A	Cafeteria	10/28/2022	10/31/2022	A2J0960-04	Lead	ND	0.2	15	ppb
126-DF1913-A-007-A	Hallway (Robotics Lab)	10/28/2022	10/31/2022	A2J0960-05	Lead	ND	0.2	15	ppb
126-DF1916-A-007-A	Auditorium (Foyer)	10/28/2022	10/31/2022	A2J0960-06	Lead	ND	0.2	15	ppb
126-DF1917-NA-007-A	Office	10/28/2022	10/31/2022	A2J0960-18	Lead	0.540	0.2	15	ppb
126-DF1918-A-007-A	Hallway (Faculty Room)	10/28/2022	10/31/2022	A2J0960-07	Lead	ND	0.2	15	ppb
126-DF1923-A-007-A	Gym (Ticket Booth)	10/28/2022	10/31/2022	A2J0960-08	Lead	ND	0.2	15	ppb
126-DF1924-A-007-A	Gym (Snack Room)	10/28/2022	10/31/2022	A2J0960-09	Lead	ND	0.2	15	ppb
126-DF1926-A-007-A	Hallway (Classroom 138)	10/28/2022	10/31/2022	A2J0960-10	Lead	0.235	0.2	15	ppb
126-DF1927-A-007-A	Hallway (Classroom 131)	10/28/2022	10/31/2022	A2J0960-11	Lead	ND	0.2	15	ppb
126-DF1933-A-007-A	Hallway (Ceramics 245)	10/28/2022	10/31/2022	A2J0960-12	Lead	ND	0.2	15	ppb
126-DF1934-A-007-A	Hallway (Upper Choral)	10/28/2022	10/31/2022	A2J0960-13	Lead	ND	0.2	15	ppb
126-DF1935-A-007-A	Hallway (Chemistry 239)	10/28/2022	10/31/2022	A2J0960-14	Lead	ND	0.2	15	ppb
126-DF1936-A-007-A	Hallway (Science 236)	10/28/2022	10/31/2022	A2J0960-15	Lead	ND	0.2	15	ppb
126-DF6041-NA-007-A	Custodian Break Room	10/28/2022	10/31/2022	A2J0960-19	Lead	0.463	0.2	15	ppb
126-DF6043-A-007-A	Cafeteria	10/28/2022	10/31/2022	A2J0960-16	Lead	0.233	0.2	15	ppb
126-DF6046-NA-007-A	Health Room	10/28/2022	10/31/2022	A2J0960-20	Lead	1.66	0.2	15	ppb
126-DF6047-NA-007-A	Snack Room	10/28/2022	10/31/2022	A2J0960-21	Lead	3.22	0.2	15	ppb
126-DF6051-NA-007-A	Field Snack Shop	10/28/2022	10/31/2022	A2J0960-22	Lead	0.442	0.2	15	ppb
126-DF6052-A-007-A	Track and Field (Snack S	10/28/2022	10/31/2022	A2J0960-17	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1