

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Ida B Wells - Test 8**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
126-DF-1921-N/A-008-A	Life Skills (Room 141)	11/8/2022	11/9/2022	A2K0324-01	Lead	1.23	0.2	15	ppb
126-DF-6044-N/A-008-A	Kitchen	11/8/2022	11/9/2022	A2K0324-02	Lead	2.33	0.2	15	ppb
126-DF-6049-N/A-008-A	Staff Room	11/8/2022	11/9/2022	A2K0324-03	Lead	0.483	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1