

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Abernethy Elementary - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
131-DF-6004-N/A-007-A	Staff Room	4/22/2022	4/27/2022	A2D0907-01	Lead	ND	0.2	15	ppb
131-DF-6290-N/A-007-A	Kitchen	4/22/2022	4/27/2022	A2D0907-02	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb