

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Ainsworth Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
132-DF-3569-N/A-005-A	Outside	4/15/2022	4/19/2022	A2D0616-01	Lead	0.202	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb