

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Astor - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
136-DF-2811-A-003-A	Multipurpose (Room 41)	11/17/2022	11/21/2022	A2K0682-06	Lead	ND	0.2	15	ppb
136-DF-2813-A-003-A	Hallway (Classroom 34)	11/17/2022	11/21/2022	A2K0682-04	Lead	ND	0.2	15	ppb
136-DF-2819-A-003-A	Hallway (Classroom 51)	11/17/2022	11/21/2022	A2K0682-08	Lead	ND	0.2	15	ppb
136-DF-2822-N/A-003-A	Special Education	11/17/2022	11/21/2022	A2K0682-05	Lead	1.17	0.2	15	ppb
136-DF-2839-A-003-A	Hallway (Classroom 23)	11/17/2022	11/21/2022	A2K0682-02	Lead	ND	0.2	15	ppb
136-DF-2848-A-003-A	Hallway (Copy Room)	11/17/2022	11/21/2022	A2K0682-01	Lead	ND	0.2	15	ppb
136-DF-6132-N/A-003-A	Kitchen	11/17/2022	11/21/2022	A2K0682-07	Lead	0.258	0.2	15	ppb
136-DF-6133-N/A-003-A	Staff Room	11/17/2022	11/21/2022	A2K0682-03	Lead	0.814	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb