

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Bridlemile Elementary - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
142-DF-2045-A-004-A	Cafeteria	4/12/2022	4/19/2022	A2D0615-02	Lead	ND	0.2	15	ppb
142-DF-2053-N/A-004-A	Communication Behavior	4/12/2022	4/19/2022	A2D0615-07	Lead	0.294	0.2	15	ppb
142-DF-2055-A-004-A	Hallway (Classroom 43)	4/12/2022	4/19/2022	A2D0615-03	Lead	ND	0.2	15	ppb
142-DF-2063-N/A-004-A	Pre-K	4/12/2022	4/19/2022	A2D0615-08	Lead	ND	0.2	15	ppb
142-DF-2072-A-004-A	Hallway (Dining Lounge)	4/12/2022	4/19/2022	A2D0615-04	Lead	ND	0.2	15	ppb
142-DF-2074-A-004-A	Gymnasium	4/12/2022	4/19/2022	A2D0615-01	Lead	0.227	0.2	15	ppb
142-DF-2077-N/A-004-A	Communication Behavior	4/12/2022	4/19/2022	A2D0615-09	Lead	0.999	0.2	15	ppb
142-DF-2079-A-004-A	Hallway (Classroom 14A)	4/12/2022	4/19/2022	A2D0615-05	Lead	ND	0.2	15	ppb
142-DF-2081-N/A-004-A	Staff Room	4/12/2022	4/19/2022	A2D0615-10	Lead	0.835	0.2	15	ppb
142-DF-6061-N/A-004-A	Portable Staff Room	4/12/2022	4/19/2022	A2D0615-11	Lead	0.564	0.2	15	ppb
142-DF-6062-N/A-004-A	Kitchen	4/12/2022	4/19/2022	A2D0615-06	Lead	13.0	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1