

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Buckman Elementary - Test 6**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
143-DF-6005-N/A-006-A	Health Room	4/22/2022	4/25/2022	A2D0908-01	Lead	0.466	0.2	15	ppb
143-DF-6291-N/A-006-A	Kitchen	4/22/2022	4/25/2022	A2D0908-02	Lead	0.281	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental