

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Chief Joseph - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
148-DF-3038-N/A-007-A	Classroom 26	8/12/2022	8/16/2022	A2H0475-01	Lead	2.45	0.2	15	ppb
148-DF-3044-N/A-007-A	Classroom 28	8/12/2022	8/16/2022	A2H0475-02	Lead	0.551	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1