

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Forest Park Elementary - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
152-DF-1997-A-006-A	Cafeteria	4/21/2022	4/27/2022	A2D0857-01	Lead	ND	0.2	15	ppb
152-DF-2031-A-006-A	Hallway (Gymnasium)	4/21/2022	4/27/2022	A2D0857-02	Lead	0.686	0.2	15	ppb
152-DF-2034-A-006-A	Hallway (Classroom 128)	4/21/2022	4/27/2022	A2D0857-05	Lead	ND	0.2	15	ppb
152-DF-2035-A-006-A	Hallway (Classroom 202)	4/21/2022	4/27/2022	A2D0857-06	Lead	ND	0.2	15	ppb
152-DF-6069-N/A-006-A	SES Classroom	4/21/2022	4/27/2022	A2D0857-09	Lead	ND	0.2	15	ppb
152-DF-6070-A-006-A	Hallway (Media Center)	4/21/2022	4/27/2022	A2D0857-04	Lead	1.36	0.2	15	ppb
152-DF-6071-N/A-006-A	Staff Room	4/21/2022	4/27/2022	A2D0857-07	Lead	0.688	0.2	15	ppb
152-DF-6072-N/A-006-A	Health Room	4/21/2022	4/27/2022	A2D0857-08	Lead	ND	0.2	15	ppb
152-DF-6073-N/A-006-A	Kitchen	4/21/2022	4/27/2022	A2D0857-03	Lead	0.501	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1