

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Robert Gray Site - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
158-DF-4406-A-006-A	Cafeteria	8/16/2022	8/19/2022	A2H0555-01	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb