

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Hayhurst - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
160-DF-4351-N/A-004-A	SES Classroom 14	8/29/2022	9/1/2022	A2H0901-04	Lead	0.732	0.2	15	ppb
160-DF-4354-N/A-004-A	SES Classroom 26	8/29/2022	9/1/2022	A2H0901-05	Lead	1.67	0.2	15	ppb
160-DF-4356-A-004-A	Cafeteria	8/29/2022	9/1/2022	A2H0901-01	Lead	ND	0.2	15	ppb
160-DF-4357-N/A-004-A	SES Classroom 15	8/29/2022	9/1/2022	A2H0901-06	Lead	0.693	0.2	15	ppb
160-DF-4359-A-004-A	Hallway (Boiler Room)	8/29/2022	9/1/2022	A2H0901-03	Lead	ND	0.2	15	ppb
160-DF-4364-A-004-A	Hallway (Classroom 5)	8/29/2022	9/1/2022	A2H0901-09	Lead	ND	0.2	15	ppb
160-DF-4376-A-004-A	Hallway (Classroom 18)	8/29/2022	9/1/2022	A2H0901-07	Lead	ND	0.2	15	ppb
160-DF-6149-N/A-004-A	Staff Room	8/29/2022	9/1/2022	A2H0901-08	Lead	0.260	0.2	15	ppb
160-DF-6151-N/A-004-A	Kitchen	8/29/2022	9/1/2022	A2H0901-02	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1