

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Chapman - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
164-DF-3568-A-005-A	Hallway (Office)	12/2/2022	12/5/2022	A2L0136-02	Lead	ND	0.2	15	ppb
164-DF-3574-N/A-005-A	Staff Room	12/2/2022	12/5/2022	A2L0136-03	Lead	0.512	0.2	15	ppb
164-DF-3589-A-005-A	Hallway (Classroom 2)	12/2/2022	12/5/2022	A2L0136-06	Lead	ND	0.2	15	ppb
164-DF-3591-A-005-A	Hallway (Classroom 10)	12/2/2022	12/5/2022	A2L0136-04	Lead	ND	0.2	15	ppb
164-DF-3599-A-005-A	Hallway (Classroom 15)	12/2/2022	12/5/2022	A2L0136-10	Lead	ND	0.2	15	ppb
164-DF-3608-A-005-A	Hallway (Classroom 22)	12/2/2022	12/5/2022	A2L0136-08	Lead	ND	0.2	15	ppb
164-DF-6142-A-005-A	Gym Basement	12/2/2022	12/5/2022	A2L0136-01	Lead	ND	0.2	15	ppb
164-DF-6143-N/A-005-A	Kitchen	12/2/2022	12/5/2022	A2L0136-05	Lead	2.55	0.2	15	ppb
164-DF-6144-N/A-005-A	Health Room	12/2/2022	12/5/2022	A2L0136-07	Lead	1.04	0.2	15	ppb
164-DF-6146-N/A-005-A	Staff Room	12/2/2022	12/5/2022	A2L0136-09	Lead	1.92	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental