

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Humboldt - Test 3**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
164-DF-2238-A-003-A	Hallway	8/2/2022	8/9/2022	A2H0126-01	Lead	0.378	0.2	15	ppb
164-DF-2244-A-003-A	Hallway (Facility Room)	8/2/2022	8/9/2022	A2H0126-02	Lead	1.17	0.2	15	ppb
164-DF-2245-A-003-A	Hallway (Classroom 4)	8/2/2022	8/9/2022	A2H0126-03	Lead	2.71	0.2	15	ppb
164-DF-6119-N/A-003-A	Kitchen	8/2/2022	8/9/2022	A2H0126-04	Lead	0.850	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb

Page 1 of 1