

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Maplewood Elementary - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
172-DF-4377-A-004-A	Cafeteria	4/26/2022	4/28/2022	A2D1006-04	Lead	ND	0.2	15	ppb
172-DF-4383-A-004-A	Staircase (Gym)	4/26/2022	4/28/2022	A2D1006-05	Lead	ND	0.2	15	ppb
172-DF-6091-A-004-A	Hallway (Classroom 111)	4/26/2022	4/28/2022	A2D1006-02	Lead	ND	0.2	15	ppb
172-DF-6092-A-004-A	Hallway (Workroom)	4/26/2022	4/28/2022	A2D1006-01	Lead	ND	0.2	15	ppb
172-DF-6093-N/A-004-A	Kitchen	4/26/2022	4/28/2022	A2D1006-03RE1	Lead	3.74	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1