

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Rieke Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
183-DF-4457-N/A-003-A	Staff Room	4/12/2022	4/19/2022	A2D0612-06	Lead	1.47	0.2	15	ppb
183-DF-4460-A-003-A	Hallway (Classroom 12)	4/12/2022	4/19/2022	A2D0612-01	Lead	ND	0.2	15	ppb
183-DF-4468-A-003-A	Hallway (Classroom 6)	4/12/2022	4/19/2022	A2D0612-02	Lead	ND	0.2	15	ppb
183-DF-4476-A-003-A	Hallway (Multipurpose Roor	4/12/2022	4/19/2022	A2D0612-03	Lead	ND	0.2	15	ppb
183-DF-4479-A-003-A	Multipurpose Room	4/12/2022	4/19/2022	A2D0612-04	Lead	ND	0.2	15	ppb
183-DF-6101-N/A-003-A	Kitchen	4/12/2022	4/19/2022	A2D0612-05	Lead	60.6	0.2	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental