

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
West Sylvan - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
196-DF-2087-A-004-A	Hallway (Main Office)	8/30/2022	9/1/2022	A2H0939-01	Lead	ND	0.2	15	ppb
196-DF-2091-A-004-A	Hallway (Gymnasium)	8/30/2022	9/1/2022	A2H0939-06	Lead	ND	0.2	15	ppb
196-DF-2094-A-004-A	Hallway (Classroom 11)	8/30/2022	9/1/2022	A2H0939-07	Lead	ND	0.2	15	ppb
196-DF-2096-A-004-A	Hallway (Classroom 148)	8/30/2022	9/1/2022	A2H0939-05	Lead	ND	0.2	15	ppb
196-DF-2097-A-004-A	Hallway (Media Center)	8/30/2022	9/1/2022	A2H0939-04	Lead	ND	0.2	15	ppb
196-DF-2098-A-004-A	Hallway (Classroom 113)	8/30/2022	9/1/2022	A2H0939-02	Lead	ND	0.2	15	ppb
196-DF-2099-A-004-A	Hallway (Lower Gym)	8/30/2022	9/1/2022	A2H0939-08	Lead	ND	0.2	15	ppb
196-DF-6152-N/A-004-A	Staff Room	8/30/2022	9/1/2022	A2H0939-03	Lead	2.86	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental