

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Cleveland HS - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
213-DF-5872-N/A-004-A	Health Room	4/22/2022	4/27/2022	A2D0911-01	Lead	0.840	0.2	15	ppb
213-DF-5873-N/A-004-A	Kitchen	4/22/2022	4/27/2022	A2D0911-02	Lead	ND	0.2	15	ppb
213-DF-5874-N/A-004-A	Coffee Cart Room	4/22/2022	4/27/2022	A2D0911-03	Lead	0.910	0.2	15	ppb
213-DF-5875-N/A-004-A	Life Skills Room	4/22/2022	4/27/2022	A2D0911-06	Lead	0.480	0.2	15	ppb
213-DF-5877-N/A-004-A	Staff Room	4/22/2022	4/27/2022	A2D0911-05	Lead	0.269	0.2	15	ppb
213-DF-5879-N/A-004-A	Staff Room	4/22/2022	4/27/2022	A2D0911-04	Lead	1.01	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1