

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Franklin - Test 2**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
215-DF-5649-N/A-002-A	Student Learning Center	8/18/2022	8/25/2022	A2H0767-19	Lead	1.93	0.2	15	ppb
215-DF-6452-N/A-002-A	Special Ed Classroom	8/18/2022	8/25/2022	A2H0767-29	Lead	0.849	0.2	15	ppb
215-DF-6453-N/A-002-A	Life Skill 025	8/18/2022	8/25/2022	A2H0767-01	Lead	0.252	0.2	15	ppb
215-DF-6454-N/A-002-A	Life Skill 024	8/18/2022	8/25/2022	A2H0767-02	Lead	1.38	0.2	15	ppb
215-DF-6455-N/A-002-A	Teachers Cubicle Area	8/18/2022	8/25/2022	A2H0767-04	Lead	0.326	0.2	15	ppb
215-DF-6456-N/A-002-A	Teachers Office S 154	8/18/2022	8/25/2022	A2H0767-05	Lead	0.361	0.2	15	ppb
215-DF-6459-N/A-002-A	Hallway (Elevator A)	8/18/2022	8/25/2022	A2H0767-06	Lead	ND	0.2	15	ppb
215-DF-6460-N/A-002-A	Theater Concession 108	8/18/2022	8/25/2022	A2H0767-07	Lead	1.02	0.2	15	ppb
215-DF-6461-A-002-A	Student Store M118	8/18/2022	8/25/2022	A2H0767-13	Lead	0.756	0.2	15	ppb
215-DF-6461-B-002-A	Student Store M118	8/18/2022	8/25/2022	A2H0767-14	Lead	ND	0.2	15	ppb
215-DF-6462-N/A-002-A	Work Room	8/18/2022	8/25/2022	A2H0767-15	Lead	ND	0.2	15	ppb
215-DF-6463-N/A-002-A	Staff Room 126	8/18/2022	8/25/2022	A2H0767-03	Lead	ND	0.2	15	ppb
215-DF-6465-N/A-002-A	Toddler M 108	8/18/2022	8/25/2022	A2H0767-10	Lead	1.64	0.2	15	ppb
215-DF-6466-N/A-002-A	Kitchen M 107A	8/18/2022	8/25/2022	A2H0767-09	Lead	0.207	0.2	15	ppb
215-DF-6467-N/A-002-A	Changing M107B	8/18/2022	8/25/2022	A2H0767-11	Lead	ND	0.2	15	ppb
215-DF-6468-N/A-002-A	Toddler M 107	8/18/2022	8/25/2022	A2H0767-08	Lead	3.38	0.2	15	ppb
215-DF-6469-N/A-002-A	Infant M 105 A	8/18/2022	8/25/2022	A2H0767-12	Lead	0.503	0.2	15	ppb
215-DF-6470-N/A-002-A	Nurse Room	8/18/2022	8/25/2022	A2H0767-16	Lead	0.246	0.2	15	ppb
215-DF-6471-N/A-002-A	Break Room	8/18/2022	8/25/2022	A2H0767-18	Lead	0.210	0.2	15	ppb
215-DF-6472-N/A-002-A	Staff Room 127	8/18/2022	8/25/2022	A2H0767-17	Lead	1.85	0.2	15	ppb
215-DF-6473-N/A-002-A	Kitchen 102	8/18/2022	8/25/2022	A2H0767-20	Lead	0.232	0.2	15	ppb
215-DF-6474-N/A-002-A	Teacher's Office 239	8/18/2022	8/25/2022	A2H0767-26	Lead	0.237	0.2	15	ppb
215-DF-6476-N/A-002-A	Teacher's Office 217	8/18/2022	8/25/2022	A2H0767-27	Lead	0.392	0.2	15	ppb
215-DF-6477-N/A-002-A	Teacher's Office 201	8/18/2022	8/25/2022	A2H0767-25	Lead	0.930	0.2	15	ppb
215-DF-6478-N/A-002-A	Teacher's Office 239	8/18/2022	8/25/2022	A2H0767-22	Lead	5.00	0.2	15	ppb
215-DF-6479-N/A-002-A	Hallway (Gen Ed Classroom)	8/18/2022	8/25/2022	A2H0767-21	Lead	0.332	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

215-DF-6480-N/A-002-A	Student Coffee Shop	8/18/2022	8/25/2022	A2H0767-23	Lead	ND	0.2	15	ppb
215-DF-6481-N/A-002-A	Break Room	8/18/2022	8/25/2022	A2H0767-24	Lead	0.483	0.2	15	ppb
215-DF-6482-N/A-002-A	Training 021	8/18/2022	8/25/2022	A2H0767-31	Lead	0.533	0.2	15	ppb
215-DF-6485-N/A-002-A	Gym Concession	8/18/2022	8/25/2022	A2H0767-32	Lead	0.480	0.2	15	ppb
215-DF-6486-N/A-002-A	Teacher's Office 112	8/18/2022	8/25/2022	A2H0767-33	Lead	ND	0.2	15	ppb
215-DF-6487-N/A-002-A	Culinary Arts 114	8/18/2022	8/25/2022	A2H0767-34	Lead	ND	0.2	15	ppb
215-DF-6489-N/A-002-A	Hallway (Classroom 016)	8/18/2022	8/25/2022	A2H0767-28	Lead	ND	0.2	15	ppb
215-DF-6588-N/A-002-A	Concessions	8/18/2022	8/25/2022	A2H0767-30	Lead	0.700	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 2 of 2