

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Marshall Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
220-DF5236-A-005-A	Hallway (Office)	4/8/2022	4/12/2022	A2D0349-07	Lead	ND	0.2	15	ppb
220-DF5268-A-005-A	Hallway (Wellness Center)	4/8/2022	4/12/2022	A2D0349-01	Lead	ND	0.2	15	ppb
220-DF5273-A-005-A	Hallway (Mech B-31)	4/8/2022	4/12/2022	A2D0349-05	Lead	ND	0.2	15	ppb
220-DF5286-A-005-A	Cafeteria	4/8/2022	4/12/2022	A2D0349-03	Lead	ND	0.2	15	ppb
220-DF5351-A-005-A	Hallway (Nursing Room)	4/8/2022	4/12/2022	A2D0349-10	Lead	ND	0.2	15	ppb
220-DF5357-A-005-A	Hallway (C-55)	4/8/2022	4/12/2022	A2D0349-13	Lead	ND	0.2	15	ppb
220-DF6102-N/A-005-A	Staff Room	4/8/2022	4/12/2022	A2D0349-02	Lead	0.506	0.2	15	ppb
220-DF6103-N/A-005-A	Kitchen	4/8/2022	4/12/2022	A2D0349-04	Lead	1.20	0.2	15	ppb
220-DF6106-N/A-005-A	Office Staff Room	4/8/2022	4/12/2022	A2D0349-08	Lead	0.745	0.2	15	ppb
220-DF6107-N/A-005-A	Staff Room B-51	4/8/2022	4/12/2022	A2D0349-06	Lead	4.69	0.2	15	ppb
220-DF6109-N/A-005-A	Staff Room	4/8/2022	4/12/2022	A2D0349-09	Lead	2.18	0.2	15	ppb
220-DF6110-N/A-005-A	Nursing Classroom	4/8/2022	4/12/2022	A2D0349-11	Lead	0.908	0.2	15	ppb
220-DF6111-N/A-005-A	Dental Classroom	4/8/2022	4/12/2022	A2D0349-12	Lead	0.454	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental