

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Arleta Site - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
232-DF-5219-A-004-A	Hallway (Kindergarten 8)	12/6/2022	12/7/2022	A2L0201-01	Lead	0.282	0.2	15	ppb
232-DF-5907-A-004-A	Staff Room	12/6/2022	12/7/2022	A2L0201-03	Lead	1.61	0.2	15	ppb
232-DF-5908-A-004-A	Health Room	12/6/2022	12/7/2022	A2L0201-04	Lead	0.340	0.2	15	ppb
232-DF-5910-A-004-A	Kitchen (Annex)	12/6/2022	12/7/2022	A2L0201-02	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb