

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Atkinson Elementary - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
234-DF6196-N/A-007-A	Kitchen	4/8/2022	4/12/2022	A2D0340-04	Lead	0.265	0.2	15	ppb
234-DF6197-N/A-007-A	Staff Room	4/8/2022	4/12/2022	A2D0340-05	Lead	ND	0.2	15	ppb
234-DF6198-N/A-007-A	ISC Classroom 100	4/8/2022	4/12/2022	A2D0340-06	Lead	2.07	0.2	15	ppb
234-DF6200-N/A-007-A	Staff Room	4/8/2022	4/12/2022	A2D0340-01	Lead	0.452	0.2	15	ppb
234-DF6202-N/A-007-A	ISC Classroom 122	4/8/2022	4/12/2022	A2D0340-03	Lead	0.541	0.2	15	ppb
234-DF6203-N/A-007-A	Health Room	4/8/2022	4/12/2022	A2D0340-02	Lead	0.253	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb