

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Bridger Elementary - Test 8**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
238-DF-4975-A-008-A	Hallway (Gym)	5/3/2022	5/17/2022	A2E0133-02	Lead	ND	0.2	15	ppb
238-DF-5944-N/A-008-A	Health Room	5/3/2022	5/17/2022	A2E0133-01RE1	Lead	1.07	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental