

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Beverly Cleary/Fern Site - Test 8**

| <b>Sample Identification #</b> | <b>Location</b> | <b>Date/Time Collected</b> | <b>Date Analyzed</b> | <b>Lab ID</b> | <b>Analyte</b> | <b>Results</b> | <b>Detecti on Limit</b> | <b>PPS Action Level*</b> | <b>Units</b> |
|--------------------------------|-----------------|----------------------------|----------------------|---------------|----------------|----------------|-------------------------|--------------------------|--------------|
| 249-DF-1726-NA-008-A           | Common Area     | 9/21/2022                  | 9/22/2022            | A2I0663-01RE1 | Lead           | ND             | 0.200                   | 15                       | ppb          |

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb