

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Grout Elementary - Test 7**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detection Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
255-DF5979-N/A-007-A	Head Start	4/14/2022	4/19/2022	A2D0613-04	Lead	1.99	0.2	15	ppb
255-DF5980-N/A-007-A	Head Start	4/14/2022	4/19/2022	A2D0613-03	Lead	0.676	0.2	15	ppb
255-DF5981-A-007-A	Lunchroom/Gym	4/14/2022	4/19/2022	A2D0613-06	Lead	ND	0.2	15	ppb
255-DF5982-N/A-007-A	Behavior Room	4/14/2022	4/19/2022	A2D0613-02	Lead	0.259	0.2	15	ppb
255-DF5984-N/A-007-A	Behavior Room	4/14/2022	4/19/2022	A2D0613-01	Lead	0.228	0.2	15	ppb
255-DF5985-A-007-A	Hallway (Classroom 204)	4/14/2022	4/19/2022	A2D0613-05	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb

Page 1 of 1