

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Grout - Test 9**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
255-DF-6001-N/A-009-A	Health Room	8/11/2022	8/16/2022	A2H0473-01	Lead	0.502	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb