

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Irvington Elementary - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
259-DF-3856-N/A-004-A	ISC	4/29/2022	5/4/2022	A2D1150-02	Lead	0.442	0.2	15	ppb
259-DF-3866-N/A-004-A	Staff Room	4/29/2022	5/4/2022	A2D1150-01	Lead	0.793	0.2	15	ppb
259-DF-5859-N/A-004-A	Headstart	4/29/2022	5/4/2022	A2D1150-05	Lead	0.581	0.2	15	ppb
259-DF-5860-N/A-004-A	Headstart	4/29/2022	5/4/2022	A2D1150-04	Lead	0.630	0.2	15	ppb
259-DF-5861-N/A-004-A	Kitchen	4/29/2022	5/4/2022	A2D1150-03RE1	Lead	0.486	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1