

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Irvington Site - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
259-DF3853-A-006-A	Hallway (106B)	9/20/2022	9/22/2022	A2I0603-02RE1	Lead	ND	0.200	15	ppb
259-DF3875-A-006-A	Hallway (205)	9/20/2022	9/22/2022	A2I0603-03RE1	Lead	ND	0.200	15	ppb
259-DF3881-A-006-A	Hallway (209)	9/20/2022	9/22/2022	A2I0603-01RE1	Lead	ND	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1