

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Irvington - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
259-DF-5862-N/A-007-A	Health Room	10/11/2022	10/13/2022	A2J0319-01	Lead	1.07	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb