

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Lee Elementary School - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
264-DF-5845-N/A-007-A	Headstart	11/23/2021	11/29/2021	A1K1078-01	Lead	0.444	0.2	15	ppb
264-DF-6095-N/A-007-A	Staff Room	11/23/2021	11/29/2021	A1K1078-02	Lead	1.07	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb