

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Lewis Elementary School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
267-DF6184-N/A-005-A	Kitchen	4/8/2022	4/16/2022	A2D0337-03	Lead	ND	0.2	15	ppb
267-DF6185-N/A-005-A	Staff Room (Storage)	4/8/2022	4/16/2022	A2D0337-01	Lead	1.14	0.2	15	ppb
267-DF6186-N/A-005-A	Health Room	4/8/2022	4/16/2022	A2D0337-02	Lead	0.696	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb