

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Sacajawea - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
368-DF-2210-A-005-A	Hallway (Family Services)	5/20/2022	5/31/2022	A2E0852-09	Lead	ND	0.2	15	ppb
368-DF-2211-N/A-005-A	Headstart 103	5/20/2022	5/31/2022	A2E0852-08	Lead	1.76	0.2	15	ppb
368-DF-2212-N/A-005-A	Headstart 104	5/20/2022	5/31/2022	A2E0852-07	Lead	1.57	0.2	15	ppb
368-DF-2213-N/A-005-A	Headstart 105	5/20/2022	5/31/2022	A2E0852-06	Lead	0.959	0.2	15	ppb
368-DF-2214-N/A-005-A	Headstart 106	5/20/2022	5/31/2022	A2E0852-04	Lead	1.87	0.2	15	ppb
368-DF-2218-A-005-A	Hallway (Playroom)	5/20/2022	5/31/2022	A2E0852-02	Lead	ND	0.2	15	ppb
368-DF-2219-N/A-005-A	Headstart 108	5/20/2022	5/31/2022	A2E0852-05	Lead	3.64	0.2	15	ppb
368-DF-2220-N/A-005-A	Staff Room	5/20/2022	5/31/2022	A2E0852-11	Lead	2.35	0.2	15	ppb
368-DF-6169-N/A-005-A	Kitchen	5/20/2022	5/31/2022	A2E0852-01	Lead	16.1	0.2	15	ppb
368-DF-6170-N/A-005-A	Family Service	5/20/2022	5/31/2022	A2E0852-13	Lead	1.50	0.2	15	ppb
368-DF-6171-N/A-005-A	Headstart 101	5/20/2022	5/31/2022	A2E0852-12	Lead	3.65	0.2	15	ppb
368-DF-6172-N/A-005-A	Director's Office	5/20/2022	5/31/2022	A2E0852-10	Lead	0.683	0.2	15	ppb
368-DF-6173-N/A-005-A	Child Care 107	5/20/2022	5/31/2022	A2E0852-03	Lead	2.17	0.2	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture will remain out of service.

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental