

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Llewellyn Site - Test 8**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
269-DF-1186-A-008-A	Hallway (Main Office)	4/14/2022	4/19/2022	A2D0617-02	Lead	0.630	0.2	15	ppb
269-DF-5991-N/A-008-A	S/F NIU Office	4/14/2022	4/19/2022	A2D0617-01	Lead	1.32	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb