

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Meek - Test 6**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
270-DF-1397-N/A-006-A	Classroom 114	5/13/2022	5/24/2022	A2E0522-07RE1	Lead	3.26	0.2	15	ppb
270-DF-1401-N/A-006-A	Classroom 110B	5/13/2022	5/24/2022	A2E0522-06	Lead	0.526	0.2	15	ppb
270-DF-1404-A-006-A	Hallway (Classroom 111)	5/13/2022	5/24/2022	A2E0522-05	Lead	ND	0.2	15	ppb
270-DF-1738-A-006-A	Hallway (Classroom 105)	5/13/2022	5/24/2022	A2E0522-01	Lead	ND	0.2	15	ppb
270-DF-6174-A-006-A	Hallway (Cafeteria)	5/13/2022	5/24/2022	A2E0522-03	Lead	6.69	0.2	15	ppb
270-DF-6175-N/A-006-A	Culinary Classroom 102	5/13/2022	5/24/2022	A2E0522-02	Lead	0.455	0.2	15	ppb
270-DF-6176-N/A-006-A	Kitchen	5/13/2022	5/24/2022	A2E0522-04	Lead	0.665	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb