

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Rice - Test 2**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
274-DF-3842-N/A-002-A	Work Room 3	5/13/2022	5/24/2022	A2E0525-03	Lead	4.67	0.2	15	ppb
274-DF-3845-N/A-002-A	Work Room 6	5/13/2022	5/24/2022	A2E0525-04	Lead	3.40	0.2	15	ppb
274-DF-3848-N/A-002-A	Work Room 5	5/13/2022	5/24/2022	A2E0525-05	Lead	0.423	0.2	15	ppb
274-DF-3851-N/A-002-A	Work Room 2	5/13/2022	5/24/2022	A2E0525-02	Lead	1.84	0.2	15	ppb
274-DF-3854-N/A-002-A	Work Room 4	5/13/2022	5/24/2022	A2E0525-06	Lead	1.10	0.2	15	ppb
274-DF-3860-A-002-A	Hallway (Waiting Room)	5/13/2022	5/24/2022	A2E0525-01	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb