

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Rose City Park Site - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
278-DF4647-A-006-A	Hallway (Classroom 020)	8/10/2022	8/19/2022	A2H0345-01	Lead	ND	0.2	15	ppb
278-DF4649-A-006-A	Gymnasium	8/10/2022	8/19/2022	A2H0345-02	Lead	ND	0.2	15	ppb
278-DF4991-A-006-A	Hallway (Classroom 210)	8/10/2022	8/19/2022	A2H0345-03	Lead	ND	0.2	15	ppb
278-DF4995-A-006-A	Hallway (Storage 109)	8/10/2022	8/16/2022	A2H0345-04	Lead	ND	0.2	15	ppb
278-DF4996-A-006-A	Hallway (Custodial 008)	8/10/2022	8/16/2022	A2H0345-05	Lead	1.88	0.2	15	ppb
278-DF5704-A-006-A	Hallway (Gymnasium)	8/10/2022	8/16/2022	A2H0345-06	Lead	2.67	0.2	15	ppb
278-DF6163-N/A-006-A	Kitchen	8/10/2022	8/16/2022	A2H0345-09	Lead	0.406	0.2	15	ppb
278-DF6166-A-006-A	Hallway (Classroom 102)	8/10/2022	8/16/2022	A2H0345-07	Lead	0.715	0.2	15	ppb
278-DF6168-A-006-A	Hallway (Classroom 201)	8/10/2022	8/16/2022	A2H0345-08	Lead	2.24	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb