

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Sabin Elementary - Test 4**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
279-DF-2161-N/A-004-A	Staff Room	4/20/2022	4/25/2022	A2D0804-01	Lead	0.463	0.2	15	ppb
279-DF-5863-N/A-004-A	Kitchen	4/20/2022	4/25/2022	A2D0804-02	Lead	0.488	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb