

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Sellwood Middle - Test 8**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detection Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
283-DF-5999-A-008-A		4/14/2022	4/19/2022	A2D0611-02	Lead	2.15	0.2	15	ppb
283-DF-6000-A-008-A		4/14/2022	4/19/2022	A2D0611-01	Lead	1.60	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb

Page 1 of 1