

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Wilcox - Test 2**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
292-DF-6222-A-002-A	Staff Room	10/11/2022	10/13/2022	A2J0320-01	Lead	0.252	0.2	15	ppb
292-DF-6226-N/A-002-A	Work Room	10/11/2022	10/13/2022	A2J0320-02	Lead	2.50	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental