

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Woodmere Site - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
296-DF-5189-N/A-004-A	Behavior Room	7/28/2022	8/2/2022	A2G0808-04	Lead	0.264	0.200	15	ppb
296-DF-5192-N/A-004-A	Behavior Room	7/28/2022	8/2/2022	A2G0808-05	Lead	0.202	0.200	15	ppb
296-DF-5194-A-004-A	Cafeteria	7/28/2022	8/1/2022	A2G0808-01	Lead	ND	0.200	15	ppb
296-DF-5197-A-004-A	Hallway (Library)	7/28/2022	8/2/2022	A2G0808-02	Lead	ND	0.200	15	ppb
296-DF-5201-A-004-A	Hallway (Classroom 4)	7/28/2022	8/2/2022	A2G0808-03	Lead	ND	0.222	15	ppb
296-DF-5938-N/A-004-A	Staff Room	7/28/2022	8/2/2022	A2G0808-06	Lead	0.448	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb