

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Columbia - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
353-DF-3061-A-005-A	Hallway (Classroom 11)	5/27/2022	6/3/2022	A2E0983-01	Lead	0.406	0.2	15	ppb
353-DF-6113-N/A-005-A	Staff Room	5/27/2022	6/3/2022	A2E0983-03	Lead	0.929	0.2	15	ppb
353-DF-6115-A-005-A	Hallway (Classroom 3)	5/27/2022	6/3/2022	A2E0983-02	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb