

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
East Sylvan - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
372-DF-2038-A-004-A	Hallway (Classroom 4)	4/21/2022	4/25/2022	A2D0862-01	Lead	ND	0.2	15	ppb
372-DF-2039-A-004-A	Hallway (Classroom 9)	4/21/2022	4/25/2022	A2D0862-02	Lead	ND	0.2	15	ppb
372-DF-6084-N/A-004-A	Kitchen	4/21/2022	4/25/2022	A2D0862-04	Lead	ND	0.2	15	ppb
372-DF-6085-A-004-A	Cafeteria	4/21/2022	4/25/2022	A2D0862-03	Lead	ND	0.2	15	ppb
372-DF-6086-A-004-A	Hallway (3rd Floor)	4/21/2022	4/25/2022	A2D0862-05	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1