

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Abernathy Elementary School - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
131-DF-3515-A-006-A	Hallway (Office)	11/4/2021	11/18/2021	A1K0323-01RE1	Lead	ND	0.2	15	ppb
131-DF-1051-A-006-A	Hallway (Classroom 13)	11/4/2021	11/18/2021	A1K0323-02RE1	Lead	ND	0.2	15	ppb
131-DF-3524-A-006-A	Hallway (Auditorium)	11/4/2021	11/18/2021	A1K0323-03RE1	Lead	0.428	0.2	15	ppb
131-DF-3527-A-006-A	Cafeteria	11/4/2021	11/18/2021	A1K0323-04RE1	Lead	ND	0.2	15	ppb
131-DF-3533-A-006-A	Hallway (Classroom 5)	11/4/2021	11/18/2021	A1K0323-05RE1	Lead	ND	0.2	15	ppb
131-DF-1042-A-006-A	Hallway (Classroom 16)	11/4/2021	11/18/2021	A1K0323-06RE1	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb