

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Capitol Hill Site - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
144-DF-3945-A-004-A	Hallway (Classroom 102)	7/27/2022	7/29/2022	A2G0760-08	Lead	ND	0.200	15	ppb
144-DF-3952-A-004-A	Hallway (Custodian)	7/27/2022	7/29/2022	A2G0760-04	Lead	ND	0.200	15	ppb
144-DF-3954-A-004-A	Hallway (Gym)	7/27/2022	7/29/2022	A2G0760-01	Lead	ND	0.200	15	ppb
144-DF-3956-A-004-A	Hallway (Classroom 111)	7/27/2022	7/29/2022	A2G0760-07	Lead	ND	0.200	15	ppb
144-DF-3960-A-004-A	Cafeteria	7/27/2022	7/29/2022	A2G0760-02	Lead	ND	0.200	15	ppb
144-DF-3967-A-004-A	Hallway (Classroom 200)	7/27/2022	7/29/2022	A2G0760-05	Lead	ND	0.200	15	ppb
144-DF-6020-N/A-004-A	Kitchen	7/27/2022	7/29/2022	A2G0760-03	Lead	0.459	0.200	15	ppb
144-DF-6021-N/A-004-A	Staff Room	7/27/2022	7/29/2022	A2G0760-06	Lead	0.733	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb

Page 1 of 1