

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Duniway Elementary School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-DF-1082-A-004-A	Hallway (South Gym)	10/15/2021	10/27/2021	A1J0680-08	Lead	ND	0.2	15	ppb
244-DF-1085-A-004-A	Hallway (North Gym)	10/15/2021	10/27/2021	A1J0680-09	Lead	ND	0.2	15	ppb
244-DF-5977-N/A-004-A	Kitchen	10/15/2021	10/28/2021	A1J0680-10RE1	Lead	4.70	0.2	15	ppb

Analyzed by: Apex Laboratories  
Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb