

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Franklin - Test 3**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
215-DF-6458-N/A-003-A	Choir Room 131	10/19/2022	10/21/2022	A2J0600-01	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb