

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Grout Elementary School - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
255-DF-5983-N/A-006-A	Kitchen	10/15/2021	10/26/2021	A1J0680-01	Lead	0.222	0.2	15	ppb
255-DF-1208-A-006-A	Hallway (Classroom 102)	10/15/2021	10/26/2021	A1J0680-02	Lead	ND	0.2	15	ppb
255-DF-1195-A-006-A	Hallway (Office 117)	10/15/2021	10/26/2021	A1J0680-03	Lead	ND	0.2	15	ppb
255-DF-1197-N/A-006-A	Staff Room	10/15/2021	10/27/2021	A1J0680-04	Lead	1.01	0.2	15	ppb
255-DF-2253-A-006-A	Hallway (Classroom 111)	10/15/2021	10/27/2021	A1J0680-05	Lead	ND	0.2	15	ppb
255-DF-2255-A-006-A	Hallway (Classroom 212)	10/15/2021	10/27/2021	A1J0680-06	Lead	ND	0.2	15	ppb
255-DF-1210-A-006-A	Hallway (Headstart 12)	10/15/2021	10/27/2021	A1J0680-07	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb