

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Hosford Middle School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
257-DF-3720-A-005-A	Hallway (Classroom 4)	10/21/2021	10/26/2021	A1J0814-09	Lead	ND	0.2	15	ppb
257-DF-3716-A-005-A	Hallway (Auditorium)	10/21/2021	10/26/2021	A1J0814-10	Lead	ND	0.2	15	ppb
257-DF-3721-A-005-A	Hallway (Auditorium)	10/21/2021	10/26/2021	A1J0814-11	Lead	ND	0.2	15	ppb
257-DF-6008-N/A-005-A	Health Room	10/21/2021	10/26/2021	A1J0814-12	Lead	0.394	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb