

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Irvington Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
259-DF3841-A-005-A	Hallway (102)	9/16/2022	9/19/2022	A2I0504-01RE1	Lead	ND	0.200	15	ppb
259-DF3847-A-005-A	Hallway (105)	9/16/2022	9/21/2022	A2I0504-02	Lead	ND	0.222	15	ppb
259-DF3858-A-005-A	Hallway (87)	9/16/2022	9/19/2022	A2I0504-03RE1	Lead	ND	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb