

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Jackson Site - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
174-DF-1866-A-006-A	Hallway (D116)	7/28/2022	8/2/2022	A2G0807-01	Lead	ND	0.200	15	ppb
174-DF-1887-A-006-A	Hallway (Gymnasium)	7/28/2022	8/2/2022	A2G0807-09	Lead	ND	0.200	15	ppb
174-DF-2000-A-006-A	Wood Shop	7/28/2022	8/2/2022	A2G0807-10	Lead	ND	0.200	15	ppb
174-DF-6023-N/A-006-A	Staff Room	7/28/2022	8/2/2022	A2G0807-02	Lead	0.432	0.200	15	ppb
174-DF-6024-A-006-A	Hallway (Cafeteria)	7/28/2022	8/2/2022	A2G0807-06	Lead	ND	0.200	15	ppb
174-DF-6025-N/A-006-A	Kitchen	7/28/2022	8/2/2022	A2G0807-07	Lead	1.19	0.200	15	ppb
174-DF-6027-N/A-006-A	Staff Room (G241)	7/28/2022	8/2/2022	A2G0807-14	Lead	0.823	0.200	15	ppb
174-DF-6028-N/A-006-A	Staff Room (G220)	7/28/2022	8/2/2022	A2G0807-12	Lead	0.875	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb