

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Kelly Middle School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
258-DF-5380-A-004-A	Hallway	11/11/2021	11/17/2021	A1K0548-06	Lead	ND	0.2	15	ppb
258-DF-5333-A-004-A	Hallway	11/11/2021	11/17/2021	A1K0548-07	Lead	ND	0.2	15	ppb
258-DF-5330-A-004-A	Hallway	11/11/2021	11/17/2021	A1K0548-08	Lead	ND	0.2	15	ppb
258-DF-5890-N/A-004-A	Classroom 25	11/11/2021	11/17/2021	A1K0548-09	Lead	0.859	0.2	15	ppb
258-DF-5893-N/A-004-A	Classroom 28	11/11/2021	11/17/2021	A1K0548-10	Lead	0.211	0.2	15	ppb
258-DF-5381-A-004-A	Hallway	11/11/2021	11/17/2021	A1K0548-11	Lead	ND	0.2	15	ppb
258-DF-5891-N/A-004-A	Classroom 23	11/11/2021	11/17/2021	A1K0548-12	Lead	0.519	0.2	15	ppb
258-DF-5892-N/A-004-A	Classroom 19	11/11/2021	11/17/2021	A1K0548-13	Lead	0.995	0.2	15	ppb
258-DF-5376-A-004-A	Hallway	11/11/2021	11/17/2021	A1K0548-14	Lead	ND	0.2	15	ppb
258-DF-5886-N/A-004-A	Nurse Room	11/11/2021	11/17/2021	A1K0548-15	Lead	0.267	0.2	15	ppb

Analyzed by: Apex Laboratories  
Reviewed by: PSI-Intertek